

**MS Word Export To Multiple PDF Files Software - Please purchase
license. SECTION 1
1.2 Results Summary
Music and Business**

ACM SURVEY RESULTS

The following homogeneous building material types were sampled as part of this survey conducted May 20, 2003. Results are summarized in the table below:

1st Floor

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF¹	COND.²	% ACM	# SAMP.	QUANTITY
01	4" Tan cove base/ mastic	Room 1055	NF	Good	Cove base =ND Mastic = ND	3	N/A
02	4" Black cove base/ mastic	All rooms and halls except 1100, 1024, 1525, 1039a, 1532a, 1055, 1085, 1571, 1047c, 1559, 1075b	NF	Good	Cove base =ND Mastic = ND	3	N/A
03	White w/tan rolled sheet flooring	1039	F	Good	15%	3	4,000 SF
04	12" x 12" Tan w/white floor tile/mastic	1593, 1055, 1573	NF	Good	Floor tile = ND Mastic = ND	3	N/A
05	1' x 1' White pinhole ceiling tile	SW entrance, 1002, 1006, 1008, 1012, 1016, 1503, 1505, 1506, 1510a, (MRR) 1514a, (WRR), 1017a, 1086, 1088, 1092, 1048, 1058, 1066, 1072, 1076, 1564, 1527, 1562, 1566, 1085, 1083, 1587, 1577, 1580, 1582, 1584, 1586, 1079, 1081, 1592, 1560	F	Good	ND	3	N/A
06	1' x 1' Ceiling tile mastic	1 st floor same as MLT 05	NF	Good	ND	3	N/A
07	9" x 9" White w/tan floor tile/ mastic	Entire 1 st floor except 1039, 1039a, 1532a, 1055, 1571, 1559, 1075b	NF	Good	Floor tile = 6% Mastic = 5%	3	28,000 SF
08	Acoustical plaster	South entrances, 1501, 1501a, 1511, 1511a, b, c, 1515, 1515a, 1510a (MRR), 1514a (WRR), 1019a, 1017a, 1082, north hall, west hall, 1525, 1525a, 1075b	NF	Good	4%	3	22,000 SF
09	2' x 4' White pinhole ceiling panel	1097	F	Good	ND	3	N/A
10	2' x 4' White crater ceiling panel	North hall, south hall, east hall, west hall, 1039	F	Good	ND	3	N/A
11	Wall texture	1501, 1501a, 1525	F	Good	ND	5	N/A
12	Brick mortar	1501, 1501a	NF	Good	ND	3	N/A
13	Drywall Joint compound	1511, 1515, 1047b, 1039a	F	Good	Drywall =ND JC = <1%	3	10,000SF
14	12" x 12" Grey w/white floor tile/mastic	1532a	NF	Good	Floor tile = ND Mastic = ND	3	N/A
15	1' x 1' White fissure ceiling tile	1573	F	Good	ND	3	N/A
16	Mastic under 1' x 1' Ceiling tile	1573	NF	Good	ND	3	N/A
17	Vent/dust tape	Southwest entrance, north hall	F	Good	ND	3	N/A

2nd Floor

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF ¹	COND. ²	% ACM	# SAMP.	QUANTITY
18	2' X 4' white crater ceiling panel	East hall, north hall, south hall (sample 59 discarded)	F	Good	ND	3	N/A
31	Drywall Joint compound	2505, 2505a, 2557, 2559	F	Good	Drywall =ND JC = ND	3	N/A
19	9" x 9" White w/tan streaks floor tile/ mastic	All rooms except 2073a (WRR), 2075a (MRR), 2091, 2099, 2605, 2525, 2023, 2557, 2559, 2047, 2047a, 2075, 2019b, 2515	NF	Good	Floor tile = 6% Mastic = 5%	3	25,000 SF
20	1' x 1' White pinhole ceiling tile	All rooms & areas except: 2565, 2567, 2569, 2571, 2573, 2575, 2577, 2579, 2581, 2583, 2585, 2587, 2589, 2591, 2593, 2595, 2597, 2599, 2601, 2073a (MRR), 2557, 2559, 2047, 2047a, 2075, 2018, (WRR), 2019b, 2534, 2109	F	Good	ND	3	N/A
21	1' x 1' Ceiling tile mastic	Same as group 20 above	F	Good	ND	3	N/A
22	2' X 4' white pinhole ceiling panel	All 2 nd floor halls	F	Good	ND	3	N/A
23	4" Black cove base/ mastic	All rooms & areas except: 2073a, (WRR), 2071 (MRR), 2572a, (WRR), 2099, 2023 (MRR), 2047, 2047a, 2075, 2019b	NF	Good	ND	3	N/A
24	4" Brown cove base/ mastic	2047, 2047a	NF	Good	Cove base=ND Mastic = ND	3	N/A
25	Acoustical plaster	All halls, 2565, 2567, 2569, 2571, 2573, 2575, 2577, 2579, 2581, 2583, 2585, 2587, 2589, 2591, 2593, 2595, 2597, 2599, 2601, 2572a, 2574a (MRR), 2075, 2019a, b, 2017a	NF	Good	4%	5	23,000 SF
26	12" x 12" Tan w/brown streaks floor tile/mastic	2047, 2047a	NF	Good	FT = 5% Mastic = 5%	3	2,500 SF
27	Off white sheet flooring	2605, 2557, 2559, 2018	NF	Good	15%	3	2,000 SF
28	1' x 1' white fissure ceiling panel	2519, 2047, 2047a	F	Good	ND	3	N/A
29	1' x 1' Ceiling tile mastic	2519, 2047, 2047a	NF	Good	ND	3	N/A
30	Hard plaster	All rooms & areas except 2023 (MRR)	NF	Good	ND	3	N/A
32	12" x 12" Tan w/white floor tile/mastic	2603	F	Good	Floor tile = ND Mastic = ND	3	N/A
33	Fiberglass wrap glue	1 st and 2 nd floor hall, room 2023, 2071	F	Good	ND	3	N/A
34	Thermal acoustical insulation	2023 penthouse and inner hallway	F	Good	4%	5	10,000 SF
35	Vent tape	South halls, 2003	F	Good	ND	3	N/A
36	½ inch TSI elbow	2023	F	Good	ND	3	N/A
37	1 inch TSI elbow	2023	F	Good	ND	3	N/A
38	Pipe lagging	2023	F	Good	ND	3	N/A
39	2 inch TSI elbow	2023	F	Good	3%	3	16
40	Pipe wrap	1 st & 2 nd floor hall, 2071	F	Good	ND	3	N/A
41	Thermal acoustical insulation	2071	F	Good	4%	5	10,000 SF
42	Vent Tape	1 st & 2 nd floor hall, 2071	NF	Good	ND	3	N/A
43	½ inch TSI elbow	2071	F	Good	ND	3	N/A
44	1 inch TSI elbow	2071	F	Good	4%	3	8
45	Pipe lagging	2071	F	Good	ND	3	N/A
46	2 inch TSI elbow	2071	F	Good	3%	3	16

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF ¹	COND. ²	% ACM	# SAMP.	QUANTITY
47	Pipe wrap	2071	F	Good	ND	3	N/A
48	Duct tape	East hall, west hall, north hall, south hall	F	Good	ND	3	N/A
49	Drywall Joint compound	1039a, 1039c	F	Good	ND	3	N/A
50	Hard plaster	1039	NF	Good	ND	3	N/A
51	TSI elbows	1039	F	Good	5%	3	8
52	TSI pipe covering	1039	F	Good	ND	3	N/A
53	Plaster spray-on	1039 sub-wall	NF	Good	ND	3	N/A

The following homogeneous building material types were sampled as part of the survey conducted November 5, 2004. Results are summarized in the table below:

November 5, 2004

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF ¹	COND. ²	% ACM	# SAMP.	QUANTITY
01	12" X 12" White with tan floor tile/ mastic	Elevator	NF	Good	FT=ND M=ND	3	80 SF

Assumed

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF ¹	COND. ²	% ACM	# SAMP.	QUANTITY
	Ceramic tile grout	Men's, women's restrooms	F	Good	Assumed	0	4,000 SF
	Vapor barrier	Men's, women's restrooms	F	Good	Assumed	0	3,000 SF
	Fire doors	Men's, women's restrooms	NF	Good	Assumed	0	8
	Black lab countertops	Rooms throughout	NF	Good	Assumed	0	

* Reviewed Jan. 2006- no changes have been made to the above tables.

¹ F = Friable; NF = Non-friable

Friability is further defined in section 4.

² Cond. = Condition Of Materials

Either good, fair or poor.

* Bay Area Air Quality Management District – identifies this material as friable for renovation and disposal purposes.