

**MS Word Export To Multiple PDF Files Software - Please purchase
license. SECTION 1
1.2 Results Summary
Boiler Plant**

ACM SURVEY RESULTS

The following homogeneous building material types were sampled as part of this survey conducted April 12, 2004. Results are summarized in the table below:

| MTL # | MATERIAL DESCRIPTION | LOCATION | F/NF ¹ | COND. ² | % ACM | # SAMP. | QUANTITY |
|-------|-------------------------------------|--|-------------------|--------------------|---------------------------------|---------|----------|
| 01 | 12' X 12' Tan floor tile and mastic | Room 3 | NF | Good | FT = 2% Mastic = ND | 3 | 225 SF |
| 02 | Skim coat with plaster | 1 st and 2 nd floors | NF | Good | ND | 3 | N/A |
| 03 | Drywall system | Rooms 3 and 9 | F | Good | Drywall = ND Joint cpd. = ND | 3 | N/A |
| 04 | 2' X 4' White fissure ceiling panel | Rooms 3 and 5 | F | Good | ND | 3 | N/A |
| 05 | 4" Black cove base and mastic | Room 3 | NF | Good | Cove base = ND Mastic = ND | 3 | N/A |

Assumed Materials

| | MATERIAL DESCRIPTION | LOCATION | F/NF ¹ | COND. ² | % ACM | # SAMP. | QUANTITY |
|--|----------------------|-------------------|-------------------|--------------------|---------|---------|----------|
| | Firedoors/frames | Entrance and exit | NF | Good | Assumed | 0 | 4 |
| | Grout (ceramic tile) | Restroom | NF | Good | Assumed | 0 | 200 SF |
| | Vapor barrier | Restroom | NF | Good | Assumed | 0 | 200 SF |
| | Mirror mastic | Restroom | NF | Good | Assumed | 0 | 2 SF |

* Reviewed Jan. 2006- no changes have been made to the above tables.

¹ F = Friable; NF = Non-friable

Friability is further defined in section 4.

² Cond. = Condition Of Materials

Either good, fair or poor.

* Bay Area Air Quality Management District – identifies this material as friable for renovation and disposal purposes.

ND = None Detected

N/A = Not Applicable

SF = Square Feet