# MS Word Export To Multiple PDF Files Software - Please purchase license.SECTION 1

1.2 Results Summary

# **Robinson Hall**

## **ACM SURVEY RESULTS**

The following homogeneous building material types were sampled as part of this survey conducted June 14, August 23, November 5, 2004. Results are summarized in the table below:

#### June 14, 2004

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF <sup>1</sup>	COND. <sup>2</sup>	% ACM	# SAMP.	QUANTITY
01	Drywall system	Throughout 1 <sup>st</sup> floor	NF	Good	DW = ND JC = <1%	3	13,000 SF
02	4" Black cove base / mastic	Room 137	NF	Good	ND	3	N/A
03	4" Tan cove base / mastic	Throughout 1 <sup>st</sup> and 2 <sup>nd</sup> fls except Rm 137	NF	Good	Cove base = ND Mastic = 2%	3	3,000 LF
04	Carpet mastic	Room 137	F	Good	ND	3	N/A
05	12' X 12' White with black floor tile/mastic	1 <sup>st</sup> floor	NF	Good	FT = ND Mastic = 5%	3	8,000 SF
06	Sink undercoating	Room 224	NF	Good	3%	3	3 SF
07	Drywall system	Throughout 2 <sup>nd</sup> floor	NF	Good	DW = ND JC = <1%	3	13,000 SF
80	4" Tan cove base / mastic	Throughout 2 <sup>nd</sup> floor	NF	Good	Cove base = ND Mastic = 3%	3	3,000 LF
09	12' X 12' White with black floor tile/mastic	Throughout 2 <sup>nd</sup> floor	NF	Good	FT = 3% Mastic = 4%	3	8,000 SF
10	HVAC tape	Room 327	F	Good	ND	3	N/A
11	Pipe elbow insulation (TSI)	Room 327	F	Good	ND	3	N/A
12	Pipe lagging (TSI)	Room 327	F	Good	10%	3	150 LF

August 23, 2004Robinson Hall

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF <sup>1</sup>	COND. <sup>2</sup>	% ACM	# SAMP.	QUANTITY
01	Stucco	Overhang on 1 <sup>st</sup> and 2 <sup>nd</sup> floors	NF	Good	ND	5	3,000 SF

## November 5, 2004

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF <sup>1</sup>	COND. <sup>2</sup>	% ACM	# SAMP.	QUANTITY
01	2' X 4' White pinhole ceiling panel	Throughout 2 <sup>nd</sup> floor	F	Good	ND	3	8,000 SF

#### **Assumed Materials**

MATERIAL DESCRIPTION	LOCATION	F/NF <sup>1</sup>	COND. <sup>2</sup>	% ACM	# SAMP.	QUANTITY
Firedoors/frames	Entrance and exit	NF	Good	Assumed	0	4 SF
Grout (ceramic ti	le) Restrooms	NF	Good	Assumed	0	900 SF
Vapor barrier	Restrooms	NF	Good	Assumed	0	500 SF
Mirror mastic	Restrooms	NF	Good	Assumed	0	8 SF

<sup>\*</sup> Reviewed Jan. 2006- no changes have been made to the above tables.

ND = None Detected

F = Friable; NF = Non-friable Friability is further defined in section 4.

Cond. = Condition Of Materials Either good, fair or poor.

<sup>\*</sup> Bay Area Air Quality Management District – identifies this material as friable for renovation and disposal purposes.