

**California State University East Bay**  
**Testing for Lead Levels in Drinking Water and Follow-up Actions**  
(updated on 07/11/2018)

Phase 1 water samples from university drinking water sources were collected during the month of June by Intertek-PSI Environmental Services and sent to a California certified laboratory for analysis. Test results are presented in the following table. The action level is set at the EPA's Maximum Contaminant Level (MCL) of 15 ppb (1 ug/liter = 1 ppb or part per billion).

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
1	Field House	Water fountain by locker room	9	No action required
2	Field House	Water fountain by Rm. 22	< 5	No action required
3	Field House	Water fountain exterior by Rm. 21	< 5	No action required
4	A&E 1 <sup>st</sup> Fl.	Water fountain by MRR 161	< 5	No action required
5	A&E 2 <sup>nd</sup> Fl.	Water fountain by Rm. 260E	< 5	No action required
6	A&E 3 <sup>rd</sup> Fl.	Water fountain by Rm. 360	< 5	No action required
7	A&E 3 <sup>rd</sup> Fl.	Sink faucet in Breakroom Rm. 392	10	No action required
8	A&E 1 <sup>st</sup> Fl.	Sink faucet in Breakroom Rm. 193	9	No action required
122	A&E 1 <sup>st</sup> Fl.	Water fountain (R) near Rms. 142/153	5	No action required
123	A&E 1 <sup>st</sup> Fl.	Water fountain (L) near Rms. 142/153	< 5	No action required
124	A&E 1 <sup>st</sup> Fl.	Sink faucet (1) in Lab 153	9	No action required
125	A&E 1 <sup>st</sup> Fl.	Sink faucet (2) in Lab 153	9	No action required
126	A&E 1 <sup>st</sup> Fl.	Sink faucet (3) in Lab 153	< 5	No action required
127	A&E 1 <sup>st</sup> Fl.	Sink faucet in Rm. 1233	11	No action required
9	CY Boiler Plant	Sink faucet in custodial sink	7	No action required
10	CY Facilities	Water fountain in office trailer	< 5	No action required
11	CY Facilities	Sink faucet in Breakroom sink	< 5	No action required
12	CY Carpenter	Water fountain	< 5	No action required
13	CY Carpenter	Sink faucet in Breakroom sink	< 5	No action required
14	MI 4 <sup>th</sup> Fl.	Sink faucet in Breakroom Rm. 4090	8	No action required
15	MI 4 <sup>th</sup> Fl.	Water fountain by Rm. 4047	< 5	No action required
16	MI 4 <sup>th</sup> Fl.	Sink faucet in Breakroom Rm. 4040	6	No action required
17	MI 4 <sup>th</sup> Fl.	Water fountain by Rm. 4106	< 5	No action required
<b>18</b>	<b>MI 3<sup>rd</sup> Fl.</b>	<b>Sink faucet in Office Rm. 3088</b>	<b>26</b>	<b>Removed from service</b>
19	MI 3 <sup>rd</sup> Fl.	Water fountain by Rm. 3074	< 5	No action required
20	MI 3 <sup>rd</sup> Fl.	Sink faucet in Breakroom Rm. 3040	5	No action required
21	MI 3 <sup>rd</sup> Fl.	Water fountain by Rm. 3106	< 5	No action required

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
22	MI 2 <sup>nd</sup> Fl.	Water fountain by Rm. 2038	< 5	No action required
23	MI 2 <sup>nd</sup> Fl.	Water fountain by Rm. 2106	< 5	No action required
24	MI 2 <sup>nd</sup> Fl.	Water fountain (ADA) by Rm. 2106	< 5	No action required
25	MI 1 <sup>st</sup> Fl.	Water fountain by Rm. 1108	< 5	No action required
121	MI 3 <sup>rd</sup> Fl.	Sink faucet in Office Rm. 3071	< 5	No action required
26	SHCS	Water fountain by Rm. 1221	9	No action required
27	SHCS	Sink faucet in Breakroom Rm. 1223	< 5	No action required
28	SHCS	Water fountain by MRR1	< 5	No action required
29	SHCS	Water fountain by Rm. 1144	< 5	No action required
30	SHCS	Water fountain by Rm. 1166	8	No action required
31	SHCS	Water fountain by Rm. 1000	< 5	No action required
32		No sample #32		
33	M&B 1 <sup>st</sup> Fl.	Water fountain by Rm. 1058	< 5	No action required
34	M&B 1 <sup>st</sup> Fl.	Water fountain by Rm. 1036	< 5	No action required
35	M&B 1 <sup>st</sup> Fl.	Water fountain by Rm. 1510A	< 5	No action required
36	M&B 1 <sup>st</sup> Fl.	Sink faucet in Rm. 1507	< 5	No action required
37	M&B 2 <sup>nd</sup> Fl.	Water fountain by Rm. 2110	< 5	No action required
38	M&B 2 <sup>nd</sup> Fl.	Water fountain by Rm. 2056	< 5	No action required
39	M&B 2 <sup>nd</sup> Fl.	Water fountain by Rm. 2036	< 5	No action required
40	RO 1 <sup>st</sup> Fl.	Water fountain	< 5	No action required
41	RO 2 <sup>nd</sup> Fl.	Sink faucet in Breakroom Rm. 224	< 5	No action required
42	Theater 1 <sup>st</sup> Fl.	Water fountain, Front Lobby near WRR (Rm. 164)	< 5	No action required
43	Theater 1 <sup>st</sup> Fl.	Water fountain, Front Lobby near MRR (Rm. 163)	< 5	No action required
44	Theater 1 <sup>st</sup> Fl.	Water fountain near Rms. 182/184	< 5	No action required
45	Theater 1 <sup>st</sup> Fl.	Water fountain	< 5	No action required
46	Theater 2 <sup>nd</sup> Fl.	Water fountain near Rm. 286	6	No action required
47	Old Union	Water fountain near Rm. 127	< 5	No action required
48	Old Union	Water fountain near Rm. 315	< 5	No action required
49	Old Union	Sink faucet in Rm. 310	< 5	No action required
50	New Union	Water fountain (L) near 100A	< 5	No action required
51	New Union	Water fountain (R) near 100A	< 5	No action required
52	New Union	Water fountain (L) near 2010	< 5	No action required
53	New Union	Water fountain (R) near 2010	< 5	No action required
54A	New Union	Sink faucet in Office 211	< 5	No action required

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
54B	KPE 2 <sup>nd</sup> Fl.	Water fountain in Gym Rm. 202	< 5	No action required
55	KPE 2 <sup>nd</sup> Fl.	Water fountain in Rm. 201A (R)	12	No action required
56	KPE 2 <sup>nd</sup> Fl.	Water fountain in Rm. 201A (L)	7	No action required
57	KPE 1 <sup>st</sup> Fl.	Sink faucet in Rm. 139	< 5	No action required
58	KPE 1 <sup>st</sup> Fl.	Water fountain near Rm. 139 (L)	< 5	No action required
59	KPE 1 <sup>st</sup> Fl.	Water fountain near Rm. 139 (R)	< 5	No action required
60	KPE 1 <sup>st</sup> Fl.	Water fountain Wm. Locker Rm. 169	12	No action required
<b>61</b>	<b>KPE 1<sup>st</sup> Fl.</b>	<b>Water fountain in Men's Faculty Locker Rm. 181 near entrance</b>	<b>27</b>	<b>Removed from service</b>
62	KPE 1 <sup>st</sup> Fl.	Water fountain in hallway by Rm. 177	< 5	No action required
63	KPE 1 <sup>st</sup> Fl.	Water fountain in Men's Locker Rm. 189 near entrance, shower side	< 5	No action required
64	KPE 1 <sup>st</sup> Fl.	Water fountain in Men's Locker Rm. 189 rear, shower side	6	No action required
<b>65</b>	<b>KPE 1<sup>st</sup> Fl.</b>	<b>Water fountain in Men's Locker Rm. 189 near exit to pool (rear east wall)</b>	<b>18</b>	<b>Removed from service</b>
<b>66</b>	<b>KPE 1<sup>st</sup> Fl.</b>	<b>Water fountain in Men's Locker Rm. 189 ( front east wall)</b>	<b>80</b>	<b>Removed from service</b>
67	KPE 1 <sup>st</sup> Fl.	Water fountain Main Gym 145 (NE)	< 5	No action required
68	KPE 1 <sup>st</sup> Fl.	Water fountain Main Gym 145 (NW)	12	No action required
69	KPE 1 <sup>st</sup> Fl.	Water fountain Main Gym 145 (SE)	< 5	No action required
70	KPE 1 <sup>st</sup> Fl.	Water fountain Main Gym 145 (SW)	< 5	No action required
71	KPE 1 <sup>st</sup> Fl.	Sink faucet in Rm. 130E	< 5	No action required
72	KPE 1 <sup>st</sup> Fl.	Water fountain by MRR and Rm. 102	8	No action required
<b>73</b>	<b>Science 4<sup>th</sup> Fl.</b>	<b>Water fountain near Rm. N446</b>	<b>40</b>	<b>Removed from service</b>
74	Science 4 <sup>th</sup> Fl.	Water fountain near Rm. S429	< 5	No action required
<b>75</b>	<b>Science 4<sup>th</sup> Fl.</b>	<b>Water fountain near Rm. S406</b>	<b>24</b>	<b>Removed from service</b>
<b>76</b>	<b>Science 4<sup>th</sup> Fl.</b>	<b>Water fountain near Rm. S442</b>	<b>21</b>	<b>Removed from service</b>
<b>77</b>	<b>Science 3<sup>rd</sup> Fl.</b>	<b>Water fountain near Rm. S306</b>	<b>16</b>	<b>Removed from service</b>
<b>78</b>	<b>Science 3<sup>rd</sup> Fl.</b>	<b>Water fountain near Rm. S347</b>	<b>50</b>	<b>Removed from service</b>
79	Science 3 <sup>rd</sup> Fl.	Water fountain near Rm. S327	< 5	No action required
<b>80</b>	<b>Science 3<sup>rd</sup> Fl.</b>	<b>Water fountain near Rm. N347</b>	<b>50</b>	<b>Removed from service</b>
81	Science 3 <sup>rd</sup> Fl.	Water fountain near Rm. N306	< 5	No action required
82	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. N233	12	No action required
<b>83</b>	<b>Science 2<sup>nd</sup> Fl.</b>	<b>Water fountain near Rm. N247</b>	<b>50</b>	<b>Removed from</b>

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
				<i>service</i>
84	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. S204	< 5	No action required
85	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. S204	< 5	No action required
<b>86</b>	<b>Science 2<sup>nd</sup> Fl.</b>	<b>Water fountain near Rm. S247</b>	<b>16</b>	<b>Removed from service</b>
<b>87</b>	<b>Science 1<sup>st</sup> Fl.</b>	<b>Water fountain near Rm. N142</b>	<b>100</b>	<b>Removed from service</b>
88	Science 1 <sup>st</sup> Fl.	Water fountain near Rm. N124	< 5	No action required
89	Science 1 <sup>st</sup> Fl.	Water fountain near Rm. S125P	< 5	No action required
NA	Science 4 <sup>th</sup> Fl.	Water fountain near Rm. N411	Not Sampled/out of service	
NA	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. S229	Not Sampled/out of service	
90	Library - UM	Water fountain near 3115 & MRR	< 5	No action required
91	Library - UM	Sink faucet in Rm. 3117	< 5	No action required
92	Library - UM	Water fountain (R) btwn 3000/3145	< 5	No action required
93	Library - UM	Water fountain (L) btwn 3000/3145	< 5	No action required
94	Library - UM	Water fountain btwn 3146/3163	< 5	No action required
95	Library - UM	Water fountain near 3162	< 5	No action required
96	Library - UM	Water fountain near 3169	< 5	No action required
97	Library - UM	Water fountain near 3183/3040	< 5	No action required
98	Library - UM	Water fountain near 3030/3040	< 5	No action required
99	Library - LM	Water fountain (R)near Starbucks	< 5	No action required
100	Library - LM	Water fountain (L)near Starbucks	< 5	No action required
101	Library - LM	Sink faucet near 2011A	< 5	No action required
102	Library - LM	Water fountain near 2019A	14	No action required
103	Library - LM	Sink faucet – in area 2019	< 5	No action required
104	Library - LM	Water fountain near 2100 near BRs	< 5	No action required
105	Library - LM	Sink faucet – in area 2125	< 5	No action required
106	Library - LM	Water fountain (R) btwn 2000/2132	< 5	No action required
107	Library - LM	Water fountain (L) btwn 2000/2132	< 5	No action required
108	Library - LM	Water fountain (R) near 2310/2350	< 5	No action required
109	Library - LM	Water fountain (L) near 2310/2350	< 5	No action required
110	Library - LM	Sink faucet in Rm. 2350	< 5	No action required
111	Library - LM	Sink faucet in Rm. 2360 staff kitchen	< 5	No action required
112	Library - LM	Sink faucet in Rm. 2800	< 5	No action required
113	Library - Bsmt	Water fountain in Rm. 1063	< 5	No action required
114	Library - Bsmt	Water fountain in Rm. 1063C	< 5	No action required
115	Library - Bsmt	Faucet sink in Rm. 1077	< 5	No action required
116	Library - Bsmt	Water fountain near 1078 and restrooms	< 5	No action required
117	Library - Bsmt	Faucet sink in Rm. 1062	< 5	No action required
118	Library - Bsmt	Water fountain near 1121B and restrooms	< 5	No action required

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
119	Library - Bsmt	Faucet sink in Rm. 1066	< 5	No action required
120	Library - Bsmt	Faucet sink in Rm. 1099A	15	No action required